


ITEM	DESCRIPTION		
1	3" NORMAL VENT FITTING		
2	8"-8 OZ. EMERGENCY VENT - SHIPPED LOOSE		
3	VENT DEFLECTOR ASSEMBLY - SHIPPED LOOSE		
4	4" FITTING		
5	3" FITTING		
6	3" FCPLG		
7	1" OVERFLOW PIPE - SHIPPED LOOSE		
8	1" PIPE UNION		
9	3" FILL FITTING		
10	FILL CONTAINMENT CHAMBER		
11)	DRIP PAN PLATFORM WITH 2" LIP		
12	1/2" DRAIN FITTING		
13	STAIRS, PLATFORM AND HANDRAIL-SHIPPED LOO		
14)	3/4" PUMPOUT PIPE		
15)	3" PIPE CAP SUMP		
16	6" WF (3)		

SECTION A-A



AUTHORIZATION

COMPANY NAME

APPROVED BY (PLEASE PRINT)

APPROVAL SIGNATURE

DATE CONTRACT NO.

= NOTES =

1. PRIMARY TANK: SHELL - 1/4" HEAD - 5/16" CONTAINMENT: 1/4"

- 2. MATERIAL MILD CARBON STEEL
- 3. TEST AT 5-7 PSIG.
- 4. ENTIRE UNIT UL LISTED.
- 5. EXTERIOR FINISH -
- 6. INTERIOR LINING -
- 7. ALL DIMENSIONS APPROXIMATE.

All rights reserved. This drawing or any part thereof must not be reproduced in any form without the written permission of Areo—Power Unitized Fueler, Inc.

AREO-POWER ®

TITLE			REV #	REV D
4000	GAL. (96") FUELER		
	NT # 4895272	CANADIAN PAT	ENT APPL	ED FOR
	DATE	DRAWN BY	DWG. NO.	
1/4"=1'	8/1/92	JF	APB	640