

DESIGN DATA





CAPACITY :	19,975 GALLONS
TYPE:	FIREGUARD® CYLINDRICAL
FIREGUARD® IS A TRADEMARK OF THE STEEL TANK INSTITUTE	
NO. REQ. --	--
OPERATING PRESSURE --	ATMOSPHERIC
TANK MATERIAL --	MILD CARBON STEEL
THICKNESS --	INNER -- HEADS: 5/16", SHELL: 1/4"
	THICKNESS -- OUTER -- HEADS: 5/16", SHELL: 1/4"
	MIN. GAUGE OR THICKNESS (PER U.L. 2085)
CONSTRUCTION --	INNER -- LAP WELD OUTSIDE ONLY
	CONSTRUCTION -- OUTER -- LAP WELD OUTSIDE ONLY
TANK TEST --	PER UL 2085
INT. FINISH --	NONE
EXT. FINISH --	SP-6 BLAST, FINISH PAINT WHITE
LABEL --	UL 2085 AND FIREGUARD® PER stl

DIKE DESIGN DATA

CAPACITY --	22,000 GALLONS
TANK MATERIAL --	MILD CARBON STEEL
THICKNESS --	ALL -- 1/4"
CONSTRUCTION --	WELDED INSIDE & OUTSIDE
FINISH --	ALL -- SAME AS TANK EXTERIOR

NOTE: ALL DIMENSIONS APPROXIMATE

- SHIP LOOSE
- (2) 10" FLANGED EMERGENCY VENTS
- (1) VENT DEFLECTOR



ITEM	QTY	DESCRIPTION	ITEM	QTY	DESCRIPTION
1	1	2" MONITOR PIPE WITH MALE NPT END	7	1	10" RFSO 150# FLANGE THROUGH OUTER SHELL ONLY, MARK WITH SPECIAL WARNING LABEL INTERSTITIAL EMERGENCY VENT USE ONLY
2	5	4" FEMALE FG COUPLING	8	1	4" FEMALE FG COUPLING w/ 4" DROP PIPE TO WITHIN 6" OF THE BOTTOM OF THE TANK, MITER 45°
3	2	10" FLANGED EMERGENCY VENT (SHIP LOOSE)	9	1	FILL CONTAINMENT CHAMBER
4	1	EMERGENCY VENT PROTECTION HOOD & CHUTE	10	1	10" RFSO 150# FLANGE - FOR PRIMARY EMERGENCY VENT USE ONLY
5	6	2" FITTING THROUGH OUTER SHELL ONLY WITH CAST IRON PLUG- MFG USE ONLY	11	1	24" WIDE x 108" STAIRS w/ 1" FIBERGLASS GRATING, BOLT TO TANK, PAINT: SAFETY YELLOW, SHIP LOOSE, INSTALLATION ON SITE BY OTHERS.
6	1	6" FEMALE FG COUPLING	17	1	1" PIPE UNION

AREO-POWER®

PATENT NUMBER 5346093

20,000 GAL 120" Ø CYL. FIREGUARD® DIKE

PATENT: 5,695,089 PATENT: 5,809,650

CUSTOMER:

PROJECT:

QUOTE NO:

SCALE: 1/8"=1'-0"

DATE:

DWG. BY: AP20000FC120DIKE

CHK'D BY:

NOTE: ALL RIGHTS RESERVED. THIS DRAWING MUST NOT BE REPRODUCED IN ANY FORM WITHOUT THE WRITTEN PERMISSION OF AREO-POWER®. AREO-POWER® SHALL BE RESPONSIBLE ONLY FOR ITEMS INDICATED ON THIS FABRICATION DRAWING UNLESS OTHERWISE NOTED. CUSTOMER IS RESPONSIBLE FOR VERIFYING CORRECTNESS OF SIZE AND LOCATION OF FITTINGS, ACCESSORIES, AND COATINGS SHOWN ON THIS DRAWING.

TOUCH UP OF FINISHED PAINT IS REQUIRED BY INSTALLATION CONTRACTOR. TOUCH UP PAINT SHIPPED WITH TANK.